

Building Code	Common Building Name	Fully Captured*	Total Use (GJ)	Electricity Use (kWh)	Carbon (Kg CO ₂ -e)	Energy Density (MJ/m ²) **	History Average Deviation ***
AA.AA01	40-42 Melville St (42 Melville St, Podium & Biscuit Works)	Yes	5,904	1,639,863	213,182	746	17%
AA.AA04	135-137A Elizabeth Street	Yes	7	2,076	270	16	No historic data
AA.GY01	exMcCanns	Yes	45	12,598	1,638	31	-9%
AA.GY02	Goodyear site (Argyle St)	Yes	47	13,072	1,699	98	-51%
AC.FH02	Fountainside Accommodation	Yes	1,895	402,978	75,301	964	53%
AF.AF02	103 Melville St (exK&D)	Yes	660	183,460	23,850	643	6%
AH.AH01	137 Harrington Street	Yes	156	43,426	5,645	236	No historic data
AH.AH02	100 Melville Street	Yes	315	87,475	11,372	292	27%
AI.AI01	60 Argyle Street	Yes	491	136,370	17,728	426	No historic data
AJ.AJ02	35-37 Bathurst Street	Yes	14	4,015	522	No space data	No historic data
AJ.AJ03	31-33 Bathurst Street	Yes	2	588	76	No space data	No historic data
BB.BB01	Bell Bay site	Yes	221	41,067	9,769	622	-58%
BH.RC01	North West Rural Clinical School	Yes	583	161,828	21,038	519	-3%
BI	Bisdee Tier site	Yes	215	59,646	7,754	685	69%
BP.BP11	Seamanship Centre and Workshops	Yes	1,066	296,078	38,490	447	-4%
CA.CA01	Centre for the Arts	Yes	6,534	1,061,487	277,778	555	7%
CD.CD01	Ceduna Building	Yes	187	51,905	6,748	No space data	-3%
DM.DM01	Domain House	Yes	3	770	100	No space data	-58%
DM.DM02	Electrical Engineering	Yes	772	128,119	32,651	918	18%
DM.DM03	Waterworth Building	Yes	45	12,375	1,609	No space data	-17%
DM.DM04	Graphics	Yes	7	1,853	241	No space data	22%
DM.DM05	LARC Building	Yes	3	904	118	No space data	-28%
DM.DM07	Pottery Building	Yes	0	0	0	No space data	-100%
DM.DM09	Philip Smith Centre	Yes	1	267	35	1	No historic data
ER.ER03	Dairy Parlour and Rotary Dairy	Yes	879	244,250	31,752	No space data	57%
FS.FS10	Offices (Power exc irrigation pumps)	Yes	97	27,015	3,512	No space data	10%
HD.HD01	The Hedberg	Yes	5,989	1,663,585	216,266	544	38%
HD.HD03	Campbell St Accommodation (Theatre Royal Hotel)	Yes	15	4,263	554	No space data	-85%

Building Code	Common Building Name	Fully Captured*	Total Use (GJ)	Electricity Use (kWh)	Carbon (Kg CO ₂ -e)	Energy Density (MJ/m ²) **	History Average Deviation ***
IR.IR01	Stone Building and Annexe	Yes	2,759	755,215	100,227	523	23%
IR.IR07	Inveresk Apartments	Yes	1,493	414,710	53,912	427	-1%
IR.IR08	Railway Cottage	Yes	123	34,069	4,429	No space data	31%
IR.IR09	Northen Store	Yes	44	12,110	1,574	No space data	No historic data
IR.IR10	Library	Yes	1,394	387,276	50,346	529	No historic data
IR.IR11	Rivers Edge	Yes	1,059	294,033	38,224	216	No historic data
KA.KA01	Katherine (CDU)	Yes	217	60,158	7,820	No space data	30%
LA.LA01	8 Palmers Rd, Latrobe Accom	Yes	87	24,191	3,145	324	-1%
ML.ML01	Melville Street Apartments	Yes	8,218	1,476,901	341,479	583	4%
MP.MP01	Mt. Pleasant Observatory	Yes	683	189,728	24,665	992	-11%
MR.AG10	Residential Unit 6, Mooreville Road	Yes	85	23,508	3,056	442	-21%
MR.AG11	Residential Unit 5, Mooreville Road	Yes	123	34,137	4,438	642	15%
MR.AH08	Residential Unit 1, Mooreville Road	Yes	97	26,883	3,495	506	-9%
MR.AH09	Residential Unit 2, Mooreville Road	Yes	99	27,579	3,585	519	-1%
MR.AH10	Residential Unit 3, Mooreville Road	Yes	129	35,704	4,642	672	39%
MR.AH11	Residential Unit 4, Mooreville Road	Yes	125	34,657	4,505	652	37%
MR.CC	Cradle Coast Campus (exc apartments)	Yes	1,409	306,039	58,375	324	-44%
MS.MS01	Medical Science 1	Yes	9,315	1,853,144	377,116	1376	10%
MS.MS02	Medical Science 2	Yes	11,772	1,801,510	506,611	1758	19%
MT.MW01	Mt Nelson-Microwave Tower	Yes	23	6,384	830	No space data	No historic data
MT.MW12	Notley Hill-Microwave Tower	Yes	5	1,406	183	No space data	No historic data
NH.AE31	NRAS Block D	Yes	640	177,725	23,104	499	2%
NH.AE32	NRAS Block C	Yes	754	209,526	27,238	560	0%
NH.AE34	NRAS Block B	Yes	488	135,580	17,625	553	5%
NH.AE35	NRAS Block A	Yes	478	132,724	17,254	593	2%
NH.AF35	NRAS Block Laundry	Yes	138	38,463	5,000	1920	14%
NH.AG30	Cavitation Research Laboratory	Yes	528	146,725	19,074	784	-21%
NH.AG33	Residence Block 8	Yes	431	119,812	15,576	793	91%
NH.AG34	Residence Block 9	Yes	236	65,587	8,526	432	-5%
NH.AH25	Building T43 - Clubrooms	Yes	161	44,597	5,798	745	11%
NH.AH36	Residence Block 10	Yes	622	172,665	22,446	863	-9%

Building Code	Common Building Name	Fully Captured*	Total Use (GJ)	Electricity Use (kWh)	Carbon (Kg CO ₂ -e)	Energy Density (MJ/m ²) **	History Average Deviation ***
NH.AI31	Model Test Basin	Yes	281	77,937	10,132	390	-6%
NH.AI33	Residence Block 2, 3 & 4	Yes	808	224,334	29,163	872	20%
NH.AJ21	Building T40B	Yes	112	31,188	4,054	5605	54%
NH.AJ22	Building T42- Changerooms	Yes	1	188	24	4	-80%
NH.AJ31	AUV Lab	Yes	66	18,300	2,379	211	14%
NH.AJ35	Residence Block 7	Yes	190	52,788	6,862	544	-17%
NH.AK34	Residence Block 5 & 6	Yes	553	153,713	19,983	896	18%
NH.AL34	Residence Office 2	Yes	161	44,851	5,831	7091	5%
NH.AM32	Survival Centre	Yes	2,206	612,852	79,671	1660	31%
NH.AN21	Building T30-AFRDI	Yes	910	252,640	32,843	845	8%
NH.AN28	exCav Building (Labs)	Yes	81	22,476	2,922	167	-34%
NH.AO10	Childcare Centre	Yes	318	88,354	11,486	563	10%
NH.AO14	Childcare Cottage	Yes	15	4,213	548	113	-41%
NH.AO16	Building T1,T5,T18,T7	Yes	67	18,502	2,405	132	76%
NH.AO24	Building S	Yes	2,389	663,687	86,279	905	17%
NH.AO32	Stables 1,2,3	Yes	248	68,925	8,960	587	125%
NH.AO37	Master Of Residence	Yes	75	20,743	2,697	716	-39%
NH.AP26	Electro Technology Laboratory	Yes	147	40,902	5,317	272	-57%
NH.AP30	AMC Communal Centre	Yes	861	239,216	31,098	711	-44%
NH.AP40	Riverside Cottage	Yes	103	28,489	3,704	792	123%
NH.AQ34	Newnham Hall	Yes	482	133,946	17,413	1273	11%
NH.AR26	Thermo Dynamics	Yes	138	27,705	6,311	386	8%
NH.AR29	Connell Building	Yes	988	274,430	35,676	859	15%
NH.AR30	Simulator	Yes	1,263	350,757	45,598	1342	5%
NH.AR32	Norfolk Hall	Yes	768	213,346	27,735	973	-9%
NH.AS17	Building T9-University Sports Centre	Yes	420	116,540	15,150	272	-9%
NH.AS23	Building V-Computing	Yes	717	196,990	26,018	476	-41%
NH.AT17	Building T8-AMS Office	Yes	150	41,703	5,421	405	-22%
NH.AT19	Building R-Aquaculture	Yes	829	230,228	29,930	488	-7%
NH.AU10	Building Q2 Leprena S	Yes	185	51,478	6,692	328	-57%
NH.AU23	Building P Kerslake Hall	No	290	80,449	10,458	399	-81%

Building Code	Common Building Name	Fully Captured*	Total Use (GJ)	Electricity Use (kWh)	Carbon (Kg CO ₂ -e)	Energy Density (MJ/m ²) **	History Average Deviation ***
NH.AV25	Building H Kerslake Hall	Yes	708	196,616	25,560	886	-25%
NH.AV29	Swanson Building	Yes	2,854	792,843	103,070	490	6%
NH.AW08	Building-Q3 & Q4 Leprena W	Yes	208	57,646	7,494	365	-50%
NH.AW10	Building-Q5 Leprena Community Centre	Yes	17	4,662	606	223	-49%
NH.AW12	Building-Q1 Leprena Q	Yes	777	215,929	28,071	542	-29%
NH.AX23	Building O-Psychology	Yes	137	37,996	4,939	488	-14%
NH.AX24	Building Y-Student Centre	No	313	86,854	11,291	274	-83%
NH.AX26	Building J-Hospital Simulation Centre	Yes	912	152,295	38,525	530	-7%
NH.AY23	Building N-Nursing	Yes	811	138,547	34,100	833	9%
NH.AY27	Building E-Engineering	Yes	379	105,250	13,683	362	-8%
NH.AZ22	Building G-Human Movement	Yes	16	4,570	594	6	-90%
NH.AZ25	Building M-Nursing	Yes	772	106,325	33,900	677	2%
NH.BA25	Building C-Human Life Sciences	Yes	1,402	201,032	61,094	680	5%
NH.BA27	Building D-Commerce/Law	Yes	844	55,766	40,403	713	14%
NH.BB22	Building B-Administration & Library and Gallery	Yes	2,505	279,023	113,592	486	9%
NH.BB24	Building F-English Language Centre	Yes	188	17,002	8,748	538	6%
NH.BE21	Building X-Ferrall Centre	Yes	624	172,506	22,589	527	-23%
NH.BF24	Building A	Yes	6,134	966,062	262,481	831	3%
NH.BH21	Demountables	Yes	88	24,504	3,186	788	No historic data
RZ.RZ01	Building 101	Yes	158	43,768	5,690	169	No historic data
RZ.RZ03	Building 104	Yes	46	12,760	1,659	227	No historic data
SA.SA02	IMAS-Salamanca	Yes	8,489	1,358,089	362,068	1575	-12%
SA.SA03	Media School, Salamanca Place	Yes	256	71,140	9,248	313	139%
SB.AC06	301 Sandy Bay Rd	Yes	38	10,581	1,376	85	-82%
SB.AD07	6 Grace St	Yes	69	19,187	2,494	342	0%
SB.AG10	Child Care	Yes	169	46,957	6,104	339	-20%
SB.AH10	Community Health Clinic	Yes	20	5,532	719	373	-33%
SB.AI08	Rugby Pavilion	Yes	10	2,659	346	69	-73%
SB.AI11	Unigym	Yes	581	161,414	20,984	282	-40%
SB.AJ10	After School Care	Yes	47	13,148	1,709	259	-9%
SB.AJ13	Old IMAS	Yes	722	200,663	26,086	634	-6%

Building Code	Common Building Name	Fully Captured*	Total Use (GJ)	Electricity Use (kWh)	Carbon (Kg CO ₂ -e)	Energy Density (MJ/m ²) **	History Average Deviation ***
SB.AK12	Cricket Pavilion	Yes	37	10,295	1,338	234	-11%
SB.AL14	Law	Yes	1,686	468,318	60,881	499	-16%
SB.AN16	Surveying	Yes	0	0	0	No space data	-100%
SB.AO20	University Club	Yes	308	85,664	11,136	551	-6%
SB.AP16	Engineering	Yes	1,725	283,823	73,139	506	-34%
SB.AQ18	Engineering Workshop	Yes	1,421	155,779	64,590	590	1%
SB.AR15	Centenary Building	Yes	2,358	655,079	85,160	553	-9%
SB.AR19	Chemistry	Yes	10,263	1,906,334	423,054	1608	-24%
SB.AR20	Pharmacy	Yes	359	99,835	12,979	442	-31%
SB.AS13	Geography-Geology & CODES	Yes	2,783	535,173	113,702	564	-28%
SB.AS25	TUU-Student Union	Yes	1,543	428,608	55,719	351	12%
SB.AT15	Mathematics	Yes	360	30,692	16,846	634	-14%
SB.AU14	Physics	Yes	2,065	389,321	84,824	563	-24%
SB.AU19	Library Morris Miller	Yes	3,454	646,220	142,089	628	5%
SB.AU28	Research House	Yes	69	19,129	2,487	236	-6%
SB.AW20	Studio Theatre	Yes	223	61,821	8,037	352	13%
SB.AW21	Administration	Yes	757	210,277	27,336	495	1%
SB.AW31	Hytten Hall	Yes	914	254,003	33,020	274	-14%
SB.AX14	Psychology Research Centre	Yes	273	75,825	9,857	319	-22%
SB.AX16	Arts Lecture Theatre	Yes	326	90,460	11,760	767	-19%
SB.AX17	Social Sciences	Yes	2,263	256,646	102,362	553	-7%
SB.AX19	University Centre	Yes	1,152	207,180	47,860	669	-18%
SB.AX24	Herbarium	Yes	126	35,080	4,560	276	-4%
SB.AX33	Commerce	Yes	802	222,864	28,972	330	12%
SB.AY31	Commerce Annexe	Yes	69	19,044	2,476	348	72%
SB.AZ16	Humanities	Yes	1,221	165,649	53,731	619	-25%
SB.BA22	Life Sciences	Yes	5,882	1,197,610	236,625	811	-27%
SB.BB26	Plant / Ag Science Glasshouse	Yes	3,720	1,033,265	134,324	2691	8%
SB.BB36	University Apartments Building 5, 6, 7, 8	Yes	1,224	340,077	44,210	352	19%
SB.BB40	Uni Aparts 1,2, Laundry & AS/ISD offices	Yes	905	245,571	32,986	745	-19%
SB.BC24	Life Sciences Annexe - TIA	Yes	863	74,441	40,321	1361	11%

Building Code	Common Building Name	Fully Captured*	Total Use (GJ)	Electricity Use (kWh)	Carbon (Kg CO ₂ -e)	Energy Density (MJ/m ²) **	History Average Deviation ***
SB.BD39	St John Fisher College	Yes	2,218	408,024	85,866	803	-15%
SB.BE20	Corporate Services Building	Yes	7,510	2,086,041	271,185	4268	-10%
SB.BE26	Old Medical Sciences	Yes	1,886	301,347	80,456	686	-27%
SB.BE39	The Village	No	346	96,085	12,491	No space data	No historic data
SB.BF21	Electrode Boiler House	Yes	2,189	607,952	79,034	No space data	11%
SB.BF31	CSIRO Forestry	Yes	922	256,126	33,296	3011	-30%
SB.BI21	Steps Building	Yes	207	57,376	7,459	568	7%
SB.BN25	Horticultural Research Centre	Yes	2,731	580,716	108,490	2650	2%
SB.BO36	Seismic Vault	Yes	6	1,679	218	No space data	-3%
SB.CC	Christ College Total	Yes	2,348	615,448	81,030	667	-24%
SB.CH60	Olinda Grove Clubrooms	Yes	44	12,096	1,573	221	4%
TT	IMAS Taroona site	Yes	15,811	4,392,064	570,968	4420	2%
UF.UF01	University Farmhouse	Yes	15	4,278	556	124	-35%
UF.UF03	Small Animal Facility (Uni Farm Facility)	Yes	1,682	467,361	60,757	8626	0%
WP.WP01	Makers Workshop	Yes	135	20,578	5,789	131	-88%
WP.WP02	Field Building (exDomestic Arts)	Yes	1,909	530,140	68,918	523	64%
WP.WP03	Student Apartments	Yes	549	152,505	19,826	427	-4%
WP.WP04	Laundry	Yes	64	17,762	2,309	302	No historic data
YG.YG01	Yarragadee	Yes	90	25,113	3,265	No space data	No historic data

* 'Fully captured' denotes if a building's energy consumption has been fully captured or not, as some are served by unmetered supplies or by central heating systems

** Energy density is based on the usable floor area (UFA) of the building.

*** N/A has been used where no historical values are available or sufficient spatial data.

NOTE: The 'Energy Density' and 'History Average Deviation' columns use a graded colour scale where dark green indicates best performance and red indicates worst performance.

